



OFFICE OF THE DEPUTY FIRE OFFICER,
PURI CIRCLE, GRAND ROAD, PURI

FORM-V
FIRE SAFETY CERTIFICATE

(See rule-13(3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No.10/2021/PREV/PRI CRL

Certificate No. 28/PRI CRL, Dated:02.11.2022

This Certificate is valid up to:01.11.2024.

(Apply for renewal at least three months before expiry)

Certified that, **Chandra Sekhar Academy**, Plot No.2330/2847, Khata No.994/270, Balighai, Puri Konark Marine Drive, Dist- Puri consisting of total one number building, was inspected by officers of the Fire Service on 01.11.2022, in presence of Shri. Sanjeeb Ku. Nayak, Secretary and it has been found to comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety Rules, 2017 and that its various floors are fit for occupancy or usage as noted hereunder against each subject to compliance to the conditions as prescribed herein below:

Sl No.	Floors	Uses
1.	G floor	Educational
2.	1 st floor	Educational

CONDITIONS:

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building or premises, should be maintained by the occupier(s) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The setbacks, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupiers(s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire drills/rehearsals should be organised at least once in six months by involving local Fire Station.
5. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all Towers/Blocks of building/premises.
6. This certificate is issued under One-Time Relaxation Scheme of Odisha Fire Service Vide Govt. Notification No.28550/CD dt.28.08.2021. As such, the plan shall be approved & the building shall be regularized at Puri Konark Development Authority.

By order of the Director of Fire Service


2/11/2022
(B.K Panda)

Deputy Fire Officer,
Puri Circle, Puri
Dated: 02.11.2021

Memo No.997/PRI CRL

Copy to Mr. Sanjeeb Ku. Nayak, Secretary, Chandra Sekhar Academy, Balighai, Puri Konark Marine Drive, Dist- Puri for information.


2/11/2022
Deputy Fire Officer,
Puri Circle, Puri
Deputy Fire Officer
Puri Circle, Pun

Memo /PRI CRL

Dated:02.11.2022

Copy to the Chief Fire Officer, Fire Prevention Wing, Odisha, Cuttack/ Fire Officer,
Central Range, Cuttack for favour of kind information.

Sd/-

Deputy Fire Officer
Puri Circle, Puri

Memo No. /PRI CRL

Dated:02.11.2022

Copy to the Planning member Puri Konark Development Authority, Puri for favour of
kind information and necessary action for approval of existing building plan and regularization
of Institute.

Sd/-

Deputy Fire Officer
Puri Circle, Puri


SECRETARY
CHANDRASEKHAR ACADEMY
BALIGHAI, PURI-2


PRINCIPAL
CHANDRASEKHAR ACADEMY
BALIGHAI, PURI-2